


OCC Approved Shutdowns for the month of August'24

[illegible]

16	OCC_216	AEGCL	220KV-AGIA-BOKO-1	AEGCL	D	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING WORK	28/Aug/2024	09:00	28/Aug/2024	16:00	25/Aug/2024 10:35	27/Aug/2024 11:19	48 Hours 44 Minutes
17	OCC_216	TSECL	132KV-MONARCHAK-UDAIPUR (BANDUAR)-1	TSECL	D	Pre-Puja shutdown	27/Aug/2024	09:00	27/Aug/2024	16:00	24/Aug/2024 14:38	26/Aug/2024 11:21	44 Hours 43 Minutes
18	OCC_216	TSECL	132KV-KAMALPUR-P K BARI-1	TSECL	D	Pre-Puja shutdown	27/Aug/2024	09:00	27/Aug/2024	16:00	24/Aug/2024 14:38	26/Aug/2024 11:21	44 Hours 43 Minutes
19	OCC_216	POWERGRID	132KV-MELRIAT-SINHUI-1	POWERGRID	D	For testing of Line Diff Relay, LBB relay & BU OC-EF relay	27/Aug/2024	09:00	27/Aug/2024	17:00	24/Aug/2024 08:42	26/Aug/2024 11:20	49 Hours 20 Minutes
20	OCC_216	POWERGRID	MAIN BAY (220) OF 220KV/132KV BALIPARA-ICT-2 AND @BALIPARA - 220KV	POWERGRID	D	AMP OF BAY EQUIPMENTS	26/Aug/2024	09:00	26/Aug/2024	18:00	23/Aug/2024 16:59	25/Aug/2024 09:10	40 Hours 11 Minutes
21	OCC_216	POWERGRID	400KV-SILCHAR-MISA-1 L/R@ MISA - 400KV	POWERGRID	D	AMP of Silchar-2 Line Reactor at Misa S/S.	26/Aug/2024	09:00	26/Aug/2024	17:00	23/Aug/2024 09:31	25/Aug/2024 09:10	47 Hours 10 Minutes
22	OCC_216	POWERGRID	400 KV BISWANATH CHARIALI II & 400 KV MISA II (408)AT BALIPARA	POWERGRID	C	For ABB make CB Auxiliary Switch replacement.	26/Aug/2024	09:00	31/Aug/2024	19:00	23/Aug/2024 09:31	25/Aug/2024 09:10	47 Hours 10 Minutes
23	OCC_216	TSECL	AGARTALA (79 TILLA) - 132KV - BUS 2	TSECL	D	Pre-Puja shutdown	25/Aug/2024	09:00	25/Aug/2024	16:00	22/Aug/2024 10:21	24/Aug/2024 11:12	48 Hours 51 Minutes
24	OCC_216	TSECL	MOHANPUR - 132KV - BUS 1	TSECL	D	Pre-Puja shutdown	25/Aug/2024	09:00	25/Aug/2024	16:00	22/Aug/2024 10:21	24/Aug/2024 11:12	48 Hours 51 Minutes
25	OCC_216	TSECL	132KV-AGARTALA (79 TILLA)-DHALABIL-1	TSECL	D	To facilitate PSD of 132 KV Agartala Bus Section - 2	25/Aug/2024	09:00	25/Aug/2024	16:00	22/Aug/2024 10:21	24/Aug/2024 11:12	48 Hours 51 Minutes
26	OCC_216	TSECL	132KV-AGARTALA (79 TILLA)-AGTCCPP-1	POWERGRID	D	To facilitate PSD of 132 KV Agartala Bus Section - 2	25/Aug/2024	09:00	25/Aug/2024	16:00	22/Aug/2024 10:21	24/Aug/2024 11:12	48 Hours 51 Minutes
27	OCC_216	TSECL	SURAJMANI NAGAR - 132KV - BUS 2	TSECL	D	Pre-Puja shutdown	24/Aug/2024	09:00	24/Aug/2024	16:00	21/Aug/2024 11:52	23/Aug/2024 10:22	46 Hours 30 Minutes
28	OCC_216	TSECL	132KV-MONARCHAK-UDAIPUR (BANDUAR)-1	TSECL	D	Pre-Puja shutdown	24/Aug/2024	09:00	24/Aug/2024	16:00	21/Aug/2024 11:52	23/Aug/2024 10:22	46 Hours 30 Minutes
29	OCC_216	POWERGRID	132KV-SILCHAR-HAILAKANDI-2	POWERGRID	D	Replacement of flash over insulator at Loc No.: 85 due to lightning fault	24/Aug/2024	08:00	24/Aug/2024	17:00	21/Aug/2024 08:35	23/Aug/2024 10:22	48 Hours 22 Minutes
30	OCC_216	POWERGRID	132KV-BADARPUR-PANCHGRAM (NEW)-1	POWERGRID	D	SAS integration of LDR relay at AEGCL Panchgram end	24/Aug/2024	08:00	24/Aug/2024	17:00	21/Aug/2024 08:58	23/Aug/2024 10:22	48 Hours 22 Minutes
31	OCC_216	POWERGRID	MAIN BAY () OF 400KV-BALIPARA-KAMENG-1 @BALIPARA - 400KV	NEEPCO	D	AMP OF BAY EQUIPMENTS	23/Aug/2024	09:00	23/Aug/2024	19:00	20/Aug/2024 08:39	22/Aug/2024 10:30	48 Hours 30 Minutes



Saksham Rithe (Assistant Manager)




Chitranshi Ghangrekar (Dy. General Manager)

49	OCC_216	AEGL	220KV-AGBPP-TINSUKIA-2	AEGL	D	PREVENTIVE MAINTENANCE AND CORRIDOR CLEANING	21/Aug/2024	09:00	21/Aug/2024	16:00	18/Aug/2024 10:48	20/Aug/2024 10:54	48 Hours 6 Minutes
50	OCC_216	AEGL	220KV-SAMAGURI-SONAPUR-1	AEGL	D	PREVENTIVE MAINTENANCE AND CORRIDOR CLEANING	21/Aug/2024	08:00	21/Aug/2024	16:00	18/Aug/2024 10:48	20/Aug/2024 10:54	48 Hours 6 Minutes
51	OCC_216	POWERGRID	TIE BAY () OF 400KV-BALIPARA-MISA-2 AND 400KV/220KV MISA-ICT-1 @MISA - 400KV	POWERGRID	D	Dismantling and retrofitting of Old Electro-mechanical LBB relays with new Numerical relays for Tie Bay (402) current integration in SCADA.	21/Aug/2024	09:00	21/Aug/2024	18:00	18/Aug/2024 09:24	20/Aug/2024 10:54	48 Hours 54 Minutes
52	OCC_216	POWERGRID	132KV-TEZU-NAMSAI-1	POWERGRID	D	For replacement of conventional porcelain Insulators by Composite Long rod Polymer insulators at Power/Deep valley/River/SH/NH Crossing locations	21/Aug/2024	08:00	21/Aug/2024	17:00	18/Aug/2024 09:24	20/Aug/2024 10:54	48 Hours 54 Minutes
53	OCC_216	POWERGRID	132KV-SILCHAR-HAILAKANDI-1	POWERGRID	D	Replacement of flash over insulator at Loc No.: 85 due to lightning fault	21/Aug/2024	08:00	21/Aug/2024	17:00	18/Aug/2024 09:24	20/Aug/2024 10:54	48 Hours 54 Minutes
54	OCC_216	TSECL	132KV-AMBASA-GAMATILLA-1	TSECL	D	Pre-Puja shutdown	20/Aug/2024	09:00	20/Aug/2024	16:00	17/Aug/2024 11:05	19/Aug/2024 10:47	47 Hours 42 Minutes
55	OCC_216	TSECL	132KV-DHARMANAGAR (MISSION TILLA)-DULLAVCHERRA-1	AEGL,TSECL	D	Pre-Puja shutdown	20/Aug/2024	09:00	20/Aug/2024	16:00	17/Aug/2024 11:05	19/Aug/2024 10:47	47 Hours 42 Minutes
56	OCC_216	AEGL	220KV-AGIA-BTPS-1	AEGL	D	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING WORK	20/Aug/2024	09:00	20/Aug/2024	16:00	17/Aug/2024 11:32	19/Aug/2024 10:47	47 Hours 15 Minutes
57	OCC_216	AEGL	220KV-JAWAHARNAGAR-SAMAGURI-1	AEGL	D	PREVENTIVE MAINTENANCE AND CORRIDOR CLEANING	20/Aug/2024	08:00	20/Aug/2024	16:00	17/Aug/2024 11:32	19/Aug/2024 10:47	47 Hours 15 Minutes
58	OCC_216	AEGL	220KV-SAMAGURI-SONABIL-2	AEGL	D	PREVENTIVE MAINTENANCE AND CORRIDOR CLEANING	20/Aug/2024	08:00	20/Aug/2024	15:00	17/Aug/2024 11:32	19/Aug/2024 10:47	47 Hours 15 Minutes
59	OCC_216	AEGL	220KV-AZARA-SARUSAJAI-1	AEGL	D	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING WORK	20/Aug/2024	08:00	20/Aug/2024	16:00	17/Aug/2024 11:32	19/Aug/2024 10:47	47 Hours 15 Minutes
60	OCC_216	POWERGRID	400KV-SILCHAR-PK BARI (STERLITE)-1	POWERGRID	D	Replacement of flash over insulators due to the lightning faults	20/Aug/2024	08:00	20/Aug/2024	18:00	17/Aug/2024 08:29	19/Aug/2024 10:47	48 Hours 47 Minutes
61	OCC_216	POWERGRID	132KV-TEZU-NAMSAI-1	POWERGRID	D	For replacement of conventional porcelain Insulators by Composite Long rod Polymer insulators at Power/Deep valley/River/SH/NH Crossing locations	20/Aug/2024	08:00	20/Aug/2024	17:00	17/Aug/2024 08:29	19/Aug/2024 10:47	48 Hours 47 Minutes
62	OCC_216	POWERGRID	132KV-SILCHAR-HAILAKANDI-1	POWERGRID	D	Replacement of flash over insulator at Loc No.: 85 due to lightning fault	20/Aug/2024	08:00	20/Aug/2024	17:00	17/Aug/2024 08:29	19/Aug/2024 10:47	48 Hours 47 Minutes
63	OCC_216	POWERGRID	400 KV BISWANATH CHARIALI 3 MAIN BAY (415) AT BALIPARA	POWERGRID	D	AMP OF BAY EQUIPMENTS	19/Aug/2024	09:00	19/Aug/2024	19:00	16/Aug/2024 12:40	18/Aug/2024 09:07	44 Hours 27 Minutes



Saksham Rithe (Assistant Manager)




Chitranshi Ghangrekar (Dy. General Manager)

64	OCC_216	POWERGRID	BTPS(NTPC) II (FUTURE) & 2X 80 MVAR BUS REACTOR III AND IVAT BONGAIGAON	POWERGRID	D	AMP OF BAY EQUIPMENTS	19/Aug/2024	09:00	19/Aug/2024	19:00	16/Aug/2024 12:40	18/Aug/2024 09:07	44 Hours 27 Minutes
65	OCC_216	TSECL	132KV-AGARTALA (79 TILLA)-ROKHIA-1	TSECL	D	Pre-Puja shutdown	19/Aug/2024	09:00	19/Aug/2024	16:00	16/Aug/2024 10:18	18/Aug/2024 09:07	46 Hours 49 Minutes
66	OCC_216	AEGL	132KV-SRIKONA-PAILAPPOL-1	AEGL	D	PREVENTIVE MAINTENANCE AND CORRIDOR CLEANING	19/Aug/2024	09:00	19/Aug/2024	16:00	16/Aug/2024 11:32	18/Aug/2024 09:07	45 Hours 35 Minutes
67	OCC_216	AEGL	220KV-SAMAGURI-SONABIL-1	AEGL	D	PREVENTIVE MAINTENANCE AND CORRIDOR CLEANING	19/Aug/2024	08:00	19/Aug/2024	15:00	16/Aug/2024 11:32	18/Aug/2024 09:07	45 Hours 35 Minutes
68	OCC_216	AEGL	220KV-AZARA-SARUSAJAI-2	AEGL	D	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING WORK	19/Aug/2024	08:00	19/Aug/2024	16:00	16/Aug/2024 11:32	18/Aug/2024 09:07	45 Hours 35 Minutes
69	OCC_216	POWERGRID	400KV-SILCHAR-PK BARI (STERLITE)-1	POWERGRID	D	Replacement of flash over insulators due to the lightning faults	19/Aug/2024	08:00	19/Aug/2024	18:00	16/Aug/2024 08:50	18/Aug/2024 09:07	47 Hours 7 Minutes
70	OCC_216	POWERGRID	132KV-TEZU-NAMSAI-1	POWERGRID	D	For replacement of conventional porcelain Insulators by Composite Long rod Polymer insulators at Power/Deep valley/River/SH/NH Crossing locations	19/Aug/2024	08:00	19/Aug/2024	17:00	16/Aug/2024 08:50	18/Aug/2024 09:07	47 Hours 7 Minutes
71	OCC_216	TSECL	P K BARI - 132KV - BUS 1	TSECL	D	Pre-Puja shutdown	18/Aug/2024	09:00	18/Aug/2024	16:00	15/Aug/2024 09:05	17/Aug/2024 08:47	46 Hours 47 Minutes
72	OCC_216	POWERGRID	132KV-IMPAL-NINGTHOUKHONG 1	MSPCL	D	For Instillation of LA,s and CVT under NERSS-XII.	17/Aug/2024	08:00	17/Aug/2024	17:00	14/Aug/2024 10:54	16/Aug/2024 10:31	47 Hours 37 Minutes
73	OCC_216	TSECL	132KV-P K BARI-PK BARI (STERLITE)-1	INDIGRID	D	Pre-Puja shutdown	17/Aug/2024	09:00	17/Aug/2024	16:00	14/Aug/2024 12:23	16/Aug/2024 10:31	46 Hours 8 Minutes
74	OCC_216	TSECL	132KV-AMBASA-KAMALPUR-1	TSECL	D	Pre-Puja shutdown	17/Aug/2024	09:00	17/Aug/2024	16:00	14/Aug/2024 12:23	16/Aug/2024 10:31	46 Hours 8 Minutes
75	OCC_216	TSECL	132KV-AGARTALA (79 TILLA)-SURAJMANI NAGAR-2	TSECL	D	Pre-Puja shutdown	17/Aug/2024	09:00	17/Aug/2024	16:00	14/Aug/2024 12:23	16/Aug/2024 10:31	46 Hours 8 Minutes
76	OCC_216	AEGL	220KV-NTPS-AMGURI-1	AEGL	D	PREVENTIVE MAINTENANCE AND CORRIDOR CLEANING	17/Aug/2024	08:00	17/Aug/2024	16:00	14/Aug/2024 10:54	16/Aug/2024 10:31	47 Hours 37 Minutes
77	OCC_216	AEGL	220KV-AZARA-BOKO-1	AEGL	D	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING WORK	17/Aug/2024	08:00	17/Aug/2024	16:00	14/Aug/2024 10:54	16/Aug/2024 10:31	47 Hours 37 Minutes
78	OCC_216	TSECL	132KV-KAMALPUR-P K BARI-1	TSECL	D	Pre-Puja shutdown	16/Aug/2024	09:00	16/Aug/2024	16:00	13/Aug/2024 14:37	15/Aug/2024 08:41	42 Hours 4 Minutes
79	OCC_216	TSECL	132KV-SURAJMANINAGAR (STERLITE)-BUDHIJANGNAGAR-1	TRIPURA	D	Pre-Puja shutdown	16/Aug/2024	09:00	16/Aug/2024	16:00	13/Aug/2024 14:37	15/Aug/2024 08:41	42 Hours 4 Minutes
80	OCC_216	AEGL	220KV-NTPS-AMGURI-1	AEGL	D	PREVENTIVE MAINTENANCE AND CORRIDOR CLEANING	16/Aug/2024	08:00	16/Aug/2024	16:00	13/Aug/2024 14:19	15/Aug/2024 08:41	42 Hours 22 Minutes
81	OCC_216	TSECL	132KV-AGARTALA (79 TILLA)-MOHANPUR-1	TSECL	D	Pre-Puja shutdown	14/Aug/2024	09:00	14/Aug/2024	16:00	11/Aug/2024 11:02	13/Aug/2024 10:44	47 Hours 42 Minutes




Saksham Rithe (Assistant Manager)




Chitranshi Ghangrekar (Dy. General Manager)

134	OCC_216	TSECL	132KV-AGARTALA (79 TILLA)-SURAJMANI NAGAR-2	TSECL	D	Pre-Puja shutdown	06/Aug/2024	09:00	06/Aug/2024	16:00	03/Aug/2024 10:20	05/Aug/2024 10:00	47 Hours 40 Minutes
135	OCC_216	AEGCL	220KV-AGBPP-TINSUKIA-1	AEGCL	D	PREVENTIVE MAINTENANCE AND CORRIDOR CLEANING	06/Aug/2024	09:00	06/Aug/2024	16:00	03/Aug/2024 10:14	05/Aug/2024 10:00	47 Hours 46 Minutes
136	OCC_216	AEGCL	220KV-AGIA-BTPS-2	AEGCL	D	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING	06/Aug/2024	09:00	06/Aug/2024	16:00	03/Aug/2024 10:14	05/Aug/2024 10:00	47 Hours 46 Minutes
137	OCC_216	AEGCL	220KV-BTPS-RANGIA-1	AEGCL	D	PREVENTIVE MAINTENANCE AND CORRIDOR CLEANING	06/Aug/2024	08:00	06/Aug/2024	16:00	03/Aug/2024 10:14	05/Aug/2024 10:00	47 Hours 46 Minutes
138	OCC_216	AEGCL	132KV-TINSUKIA-MARGHERITA_AS-1	AEGCL	D	CORRIDOR CLEANING	06/Aug/2024	08:00	06/Aug/2024	16:00	03/Aug/2024 10:14	05/Aug/2024 10:00	47 Hours 46 Minutes
139	OCC_216	POWERGRID	400 KV, 125 MVAR BUS REACTOR 5 BAY AT BONGAIGAON	POWERGRID	D	AMP of Reactor along with main Bay.	06/Aug/2024	09:00	06/Aug/2024	17:00	03/Aug/2024 11:43	05/Aug/2024 10:00	46 Hours 17 Minutes
140	OCC_216	POWERGRID	400KV-AZARA-SILCHAR	NETC	D	Modification of tripping logic of line reactor during single phase transient faults and testing of the same.	06/Aug/2024	09:00	06/Aug/2024	17:00	03/Aug/2024 11:43	05/Aug/2024 10:00	46 Hours 17 Minutes
141	OCC_216	OTPCL	PALATANA - GTG 2	OTPCL	C	Gas turbine -2 borescope inspection, annual overhaul and HRSG-2 license renewal.	05/Aug/2024	00:00	18/Aug/2024	23:59	02/Aug/2024 12:00	04/Aug/2024 11:10	47 Hours 10 Minutes
142	OCC_216	OTPCL	PALATANA - STG 2	OTPCL	C	Gas turbine -2 borescope inspection, annual overhaul and HRSG-2 license renewal.	05/Aug/2024	00:00	18/Aug/2024	23:59	02/Aug/2024 12:00	04/Aug/2024 11:10	47 Hours 10 Minutes
143	OCC_216	TSECL	132KV-KAMALPUR-DHALABIL-1	TSECL	D	Pre-Puja shutdown	05/Aug/2024	09:00	05/Aug/2024	16:00	02/Aug/2024 12:48	04/Aug/2024 11:10	46 Hours 22 Minutes
144	OCC_216	TSECL	132KV-BODHIJUNG NAGAR-JIRANIA-1	TSECL	D	Pre-Puja shutdown	05/Aug/2024	09:00	05/Aug/2024	16:00	02/Aug/2024 12:48	04/Aug/2024 11:10	46 Hours 22 Minutes
145	OCC_216	AEGCL	132KV-HAILAKANDI-PANCHGRAM (NEW)-1	AEGCL	D	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING	05/Aug/2024	09:00	05/Aug/2024	16:00	02/Aug/2024 10:04	04/Aug/2024 11:10	49 Hours 6 Minutes
146	OCC_216	AEGCL	220KV-AGIA-AZARA-1	AEGCL	D	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING WORK	05/Aug/2024	08:30	05/Aug/2024	16:30	02/Aug/2024 10:04	04/Aug/2024 11:10	49 Hours 6 Minutes
147	OCC_216	AEGCL	220KV-JAWAHARNAGAR-SAMAGURI-1	AEGCL	D	PREVENTIVE MAINTENANCE AND CORRIDOR CLEANING	05/Aug/2024	08:00	05/Aug/2024	16:00	02/Aug/2024 10:29	04/Aug/2024 11:10	48 Hours 41 Minutes
148	OCC_216	OTPCL	BUS COUPLER BAY (J) OF PALATANA - 400KV - BUS 1 AND PALATANA - 400KV - BUS 2 @PALATANA - 400KV	OTPC	C	BREAKER, ISOLATOR , CT, CVT AND LA TESTING MAINTENANCE AND TESTING	04/Aug/2024	08:00	05/Aug/2024	17:00	01/Aug/2024 15:02	03/Aug/2024 11:36	44 Hours 34 Minutes
149	OCC_216	TSECL	P K BARI - 132KV - BUS 1	TSECL	D	Pre-Puja shutdown	04/Aug/2024	09:00	04/Aug/2024	16:00	01/Aug/2024 09:26	03/Aug/2024 11:36	49 Hours 36 Minutes
150	OCC_216	TSECL	132KV-PALATANA-UDAIPUR (BANDUAR)-1	TSECL	D	Pre-Puja shutdown	04/Aug/2024	09:00	04/Aug/2024	16:00	01/Aug/2024 09:26	03/Aug/2024 11:36	49 Hours 36 Minutes



Saksham Rithe (Assistant Manager)




Chitranshi Ghangrekar (Dy. General Manager)

151	OCC_216	TSECL	132KV-AGARTALA (79 TILLA)-SURAJMANI NAGAR-1	TSECL	D	Pre-Puja shutdown	04/Aug/2024	09:00	04/Aug/2024	16:00	01/Aug/2024 09:26	03/Aug/2024 11:36	49 Hours 36 Minutes
152	OCC_216	OTPC	400KV/132KV PALATANA-ICT-1	OTPC	D	ICT-1 Transformer LV side bushing and 400kv breaker operational checks	03/Aug/2024	08:00	03/Aug/2024	17:00	31/jul/2024 10:46	02/Aug/2024 11:03	48 Hours 17 Minutes
153	OCC_216	AEGCL	132KV-SRIKONA-PAILAPPOL-1	AEGCL	D	PREVENTIVE MAINTENANCE AND CORRIDOR CLEANING	03/Aug/2024	09:00	03/Aug/2024	16:00	31/jul/2024 10:35	02/Aug/2024 11:03	48 Hours 28 Minutes
154	OCC_216	AEGCL	132KV-RUPAI-CHAPAKHOWA-1	AEGCL	D	CORRIDOR CLEANING	03/Aug/2024	07:30	03/Aug/2024	17:00	31/jul/2024 10:35	02/Aug/2024 11:03	48 Hours 28 Minutes
155	OCC_216	AEGCL	220KV-JAWAHARNAGAR-SAMAGURI-1	AEGCL	D	PREVENTIVE MAINTENANCE & CORRDOR CLEANING WORK	03/Aug/2024	08:00	03/Aug/2024	16:00	31/jul/2024 10:35	02/Aug/2024 11:03	48 Hours 28 Minutes
156	OCC_216	POWERGRID	BALIPARA - 400KV B/R 2	POWERGRID	D	AMP OF BUS REACTOR-2	02/Aug/2024	09:00	02/Aug/2024	17:00	30/jul/2024 08:54	01/Aug/2024 11:16	49 Hours 16 Minutes
157	OCC_216	MEPTCL	KHLIEHRIAT(ME) - 132KV - BUS 1	MEPTCL	D	To attend the hot spot in the R-phase BSI of 132 KV Mustem Line and Bus side maintenance works of all 132 KV Line	02/Aug/2024	10:00	02/Aug/2024	16:00	30/jul/2024 01:04	01/Aug/2024 11:16	49 Hours 16 Minutes
158	OCC_216	TSECL	132KV-SURAJMANINAGAR (STERLITE)-BUDHIJANGNAGAR-1	TRIPURA	D	Pre-Puja shutdown	02/Aug/2024	09:00	02/Aug/2024	16:00	30/jul/2024 12:42	01/Aug/2024 11:16	46 Hours 34 Minutes
159	OCC_216	TSECL	132KV-KAMALPUR-P K BARI-1	TSECL	D	Pre-Puja shutdown	02/Aug/2024	09:00	02/Aug/2024	16:00	30/jul/2024 12:42	01/Aug/2024 11:16	46 Hours 34 Minutes
160	OCC_216	AEGCL	BUS COUPLER BAY (J) OF BTPS - 220KV BUS 1 AND BTPS - 220KV - BUS 2 @BTPS - 220KV	AEGCL	D	TESTING OF CT BY PGCIL	02/Aug/2024	10:00	02/Aug/2024	13:00	30/jul/2024 11:39	01/Aug/2024 11:16	47 Hours 37 Minutes
161	OCC_216	AEGCL	220KV-AGIA-BTPS-1	AEGCL	D	PREVENTIVE MAINTENANCE & CORRDOR CLEANING WORK	02/Aug/2024	09:00	02/Aug/2024	16:00	30/jul/2024 11:39	01/Aug/2024 11:16	47 Hours 37 Minutes
162	OCC_216	POWERGRID	400 KV AZARA BAY AT BONGAIGAON	POWERGRID	D	AMP of Bay Equipment	02/Aug/2024	09:00	02/Aug/2024	17:00	30/jul/2024 08:54	01/Aug/2024 11:16	49 Hours 16 Minutes
163	OCC_216	NTPC	400KV-BGTPP-BONGAIGAON-2	POWERGRID	D	1. Line 2 CT,CVT, Wave trap & conductor checking2. Line 2 Protection checking3. Line 2 Bay PM (Bay 401)	02/Aug/2024	09:00	02/Aug/2024	18:00	30/jul/2024 07:49	01/Aug/2024 11:16	49 Hours 16 Minutes
164	OCC_216	OTPC	400KV-PALATANA-SILCHAR-1 L/R@ PALATANA - 400KV	POWERGRID	C	For Installation of Bushing Monitoring Adapters for online Monitoring System.	01/Aug/2024	08:00	02/Aug/2024	17:00	29/jul/2024 03:08	31/jul/2024 10:56	48 Hours 56 Minutes
165	OCC_216	NTPC	400KV-BGTPP-BONGAIGAON-2	POWERGRID	D	1. Line 2 CT,CVT, Wave trap & conductor checking2. Line 2 Protection checking3. Line 2 Bay PM (Bay 401)	01/Aug/2024	09:00	01/Aug/2024	18:00	29/jul/2024 03:08	31/jul/2024 10:56	48 Hours 56 Minutes



Saksham Rithe (Assistant Manager)



Chitranshi Ghangrekar (Dy. General Manager)